

SAFETY RECALL

Fluke 1AC-I VoltAlert™ Voltage Tester

First released for sale on September 29, 2009



1. Look for the model number here



2. Yellow 'Battery Check' button in white tip

3. Solid yellow clip with text 'Fluke VoltAlert'

4. Round body

This recall does not affect the Fluke 1AC-II, 1LAC-II or LVD2.

To insure you have the model that is being recalled, please verify the following things:

1. Part number on the product says Fluke 1AC-AI
2. Unit has a yellow "Battery Check" button in the white tip
3. Solid yellow clip with text 'Fluke VoltAlert'
4. Unit's body is round

The red light on the tester may not operate and fail to give an indication of live voltage. This condition may mislead a user into believing that no voltage is present when that is not the case. This safety risk could result in serious injury or death from shock, electrocution, or thermal burns.

Customers should stop using the 1AC-I VoltAlert™ voltage testers immediately and contact Fluke for instructions to return this model and receive an alternate model voltage tester. Contact Fluke at:

- www.fluke.com/1ACRecall
- 1-888-97-FLUKE (35853), 6:30 a.m. to 3:00 p.m. Pacific Time Monday–Friday